

POWER-GENERATING UNITS TO BE HOMOLOGATED FOR THE LIST C10/26 ACCORDING TO THE REQUIREMENTS OF ANNEX D OF THE TECHNICAL PRESCRIPTION C10/11 ed2.4 (15/10/2025)

2. C10/26 list with power-generating units in accordance with annex D of C10/11 ed2.4 (15/10/2025)

GLV335-02	MyGrid	Energy Storage System
-----------	--------	-----------------------

checklist ed2.4.1 (04/2026)

1	2	3	4	5	6	7	8	9	10	11					12				13				14	15			
SYNERGRID reference number (GLVxxx-yy-zzzz)	BRAND NAME	Name of the product SERIES	REFERENCE of the model / type of the unit	FIRMWARE VERSION	ONLY for units (suitable for) energy storage: Name and reference of the power control system		POWER		1-phase or 3-phase	ADDITIONAL CHARACTERISTICS					LIMITATIONS				APPLICATION				Synergrid homologation approval date				
					Only for “Small” storage PGU’s : Power control system type EnFluRi (name), and/or use of P1 port of smart meter of DSO (indication “P1”).	All other (bigger) storage PGU’s : Other power control system (name)	P _{ac,r} rated (active) power (W)	S _{max} maximum apparent power (VA)		D.3	(…)	D.4.1 Hz - 52,5 Hz	D.6.2 power response to underfrequency	D.7.2 active power reduction (PI)	0 compliant power control system provided (e.g. EnFluRi)	D.7.1 only homologated for connection to HV-network generating installations"	D.4.3 only homologated for use in module < 800W	D.9.1	(…)	only homologated as a backup power system according to §2.1.1	Solar energy	Wind energy		CHP (combined heat & power)	Energy storage	Backup power system	Other
GLV335-02-0001	MyGrid	Energy Storage System	ModuleTwo	MDSP 0.2.0.7 SDSP 0.1.0.1	Shelly Pro 3EM or P1 Port		800	800	1-phase	X	X	X	X	X				X			X	X		Plug&play	21/10/2026		